

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SDL/PHE/PND/118Dated: 03.03.24It is certified that an inspection team headed by Mr. S.N. Ram(Name of Officers with designation) from P.H.G.(Name of Department/ Office) inspected the DAV MUKHYAMANTRI PUBLIC SCHOOL
LADUVA,(Name & Address of the school) on 03.03.2024 (date of inspection) and found that the
..... (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of

Assistant Engineer

Signature with Seal: P.H.E. Sub Division

Pandariya

Name

S.N. Ram

Designation

A.E.Name & Address of the Office / Department : A.E.PHE - Pandariya

To

DAV MPS LADUVAPANDARIYA, KABIRDHAM C.G.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

54**Principal**
D.A.V.M.P.S.
Laduwa, Pandariya
Kabirdham (C.G.)



NABL-DWT-00486

Sub Divisional Water Testing Laboratory
Public Health Engineering Department, Sub.Division Pandariya
Near Purana Bus Stand in Front of Balak high school Pandariya
E-mail-aephesubdnlab@gamil.com

Test Report

Report no. SDL/PHE/PND	118	Discipline- Chemical Testing	Group- Drinking Water
Senders name & address-	Sender letter no./Date	13/03/2024	Sampled by
A.E.PHE.Sub. Division Pandariya	Sample Collection date	13/03/2024	Sampling plan & Date
	DL receipt no.	118	DL Receipt date
	Date of analysis started	13/03/2024	Date of analysis Completed
			Tejashavi sahu
			Sampling not done by Lab
			13/03/2024
			14/03/2024

Sample Details

S.N.	Sample I.D.	District/Block	Panchyat	City / Village	Habitation	Source ID /Location /GPS identification
1	1556	Pandariya	Ladangpur	Laduva	Laduva	DAV Mukhyamantri public school (H.P)
-	-	-	-	-	-	-
-	-	-	-	-	-	-
-	-	-	-	-	-	-
-	-	-	-	-	-	-

Details of parametes there test method units

S. N.	Parameters	Test method		Unit	As per IS-10500-2012 drinking water		Result of S.No.			
		IS:3025/APHA 24 th edition(2023)			Acceptabl e Limit	Permissib le Limit	1	-	-	-
		Method	Part no.		6	7				
1	Turbidity	APHA	2130-Turb.-B	NTU	1.0	5.0	1.2	-	-	-
2	Chloride	APHA	4500-Cl ⁻ B	mg/l	250	1000	31.77	-	-	-
3	Total Dissolved Solids 180 °C	APHA	2540- TDS-C	mg/l	500	2000	533.10	-	-	-
4	Total Alkalinity as CaCO3	APHA	2320-CaCO3 -B	mg/l	200	600	279.11	-	-	-
5	Calcium as Ca	APHA	3500-Ca ⁺⁺ -B	mg/l	75	200	100.19	-	-	-
6	Magnesium as mg	APHA	3500- mg ⁺⁺ B	mg/l	30	100	17.14	-	-	-
7	pH 25°C	APHA	4500-H+B	pH Scale	6.5-8.5	6.5-8.5	7.45	-	-	-
8	Total Hardness as CaCO3	APHA	2340- H-C	mg/l	200	600	320.54	-	-	-
9	Colour	APHA	2120- Col-B	HU	5	15	1	-	-	-
10	Odour	IS:3025	Part-5-2018	--	Agreeable	Agreeable	Ag	-	-	-
11	Taste	IS:3025	Part-8-2017	--	Agreeable	Agreeable	Ag	-	-	-

- The report should not be produced partly or full without approval of signatory authority of legal purposes.
- It is recommended that acceptable limit is to be implemented Values in excess of those mentioned under "acceptable" render the water no suitable but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source" in column 5 above which the sources will have to be rejected.
- The results refer only to tested samples and parameters tested. 4. In the report (A- Agreeable) and (NA-Not Agreeable)
- Samples will be stored for a period of 10 day from date of issue of report.
- This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
- Results apply to the sample as received.
- Sampling not done by Lab Staff.

Syudav
Checked By -

Issue no. -118 DL/DATE/ 15/03/2024

[Signature]
ASSISTANT ENGINEER
PUBLIC HEALTH ENGINEERING
SUB DIVISION PANDARIYA
DISTRICT-KABIRDHAM (C.G.)

[Signature]
Lab. Assistant & Quality Manager

[Signature]
Principal
D.A.V.M.P.S.
Laduwa, Pandariya
Kabirdham (C.G.)